

# Burning behaviour

The applicant:

**ROSCO IBERICA,S.A**  
Calle del Oro 76 pol ind Sur  
ES-28770 COLMENAR VIEJO MADRID

is authorized to place the label " Classification of curtains fire behaviour "  
according to the report Nº 2015AN1438.



**aitex**  
textile research institute

**FIRE BEHAVIOUR OF  
CURTAINS**

**Nº 15AN1438**

The sample reference:

**"ROSCOTEX CINTAS ATAR BLANCAS Y NEGRAS"**




has been tested according to the standards UNE-EN 1101:1996+A1:2005 (equivalent to EN 1101:1995+A1:2005) and UNE-EN 13772:2011 (equivalent to EN 13772:2011). The classification according to standard UNE-EN 13773:2003 (equivalent to EN 13773:2003) is:

**"CLASS 1"**

This document has validity until July 7th 2020.  
Alcoy July 8th 2015.



**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA



**Jordi Ferrí Pascual**  
HEAD OF FIRE DEPARTMENT

